




**CARBON
ZAPP**

CZ Service Manuals

RiD03786

**Electronic Temperature Controller
Setup MTBRX_ITBRX**





RiD03786 – Electronic Temperature Controller Setup MTBRX_ITBRX

1. CZ004936



2. CZ004940



AC1-27 INSTRUCTION FOR USE

Thank you for having chosen a LAE electronic product. Before installing the instrument, please read these instructions carefully to ensure maximum performance and safety.

DESCRIPTION

Fig. 1 - Front panel

INDICATION

OUT1 Channel 1 output
OUT2 Channel 2 output
OUT3 Channel 1 setpoint modification
OUT4 Channel 2 setpoint modification
ALM Alarm
ENTR Enter button
INCR Increase / Modify Setpoint 1 button
DECR Decrease / Standby button

INSTALLATION

The AC1-27 controller, size 72x44x47 mm (WxHxD), is to be secured to a DIN rail in such a position as to ensure that no liquid infiltrates causing serious damage and compromising safety.
 Make sure that electrical connections comply with the wiring diagrams. To reduce the effects of electromagnetic disturbance, keep the sensor and signal cables well separate from the power wires.
 Place the probe T1 inside the room in a point that truly represents the temperature of the stored product.

OPERATION

DISPLAY

During normal operation, the display shows either the temperature measured or one of the following indications:
 - Control in standby
 - Control in autotuning
 - Probe T1 overrange or failure
 - Room high temperature alarm
 - Room low temperature alarm

MENU INFO

The information available in the menu is:
 - Maximum temperature recorded
 - Minimum temperature recorded
 - Minimum temperature recorded

ACCESS TO MENU AND INFORMATION DISPLAYED

- Press and temporarily release button **ENTR**
- With button **INCR** select the data to be displayed
- Press button **ENTR** to display value
- To exit from the menu, press button **ENTR** or wait for 10 seconds
- To store the new value press button **ENTR** or wait for 10 seconds
- With button **DECR** select the data to be reset
- Display the value with button **ENTR**
- While keeping button **ENTR** pressed, use button **INCR**

CHANNEL 1 SETPOINT (display and modification of desired temperature)

- Press and release button **ENTR**: the LED L1 blinks, the display shows 1SP for 1 second and then the setpoint associated value
- Press button **INCR**: the desired value (increment) is within the minimum SPL and maximum SPH limit
- To store the new value press button **ENTR** or wait for 10 seconds
- To go back to normal mode without saving the new value, press **ENTR**

CHANNEL 2 SETPOINT

With the new value displayed, the LED L2 blinks, the display shows 2SP for 1 second if it is an absolute threshold (2SM=ABS), alternatively the display shows 2DF if it is a differential relative to setpoint 1 (2SM=REL), then the value associated to the parameter appears.

- Press button **INCR**: the desired value
- To store the new value press button **ENTR** or wait for 10 seconds
- To go back to normal mode without saving the new value, press **ENTR**

STAND-BY

Button **ENTR** when pressed for 3 seconds, allows the controller to be put on a standby or output control to be resumed (with 5B=YES only).

KEYPAD LOCK

The keypad lock avoids unintended, potentially dangerous operations, which might be attempted when the controller is operating in a public place. In the INFO menu, set parameter LCK=YES to inhibit all functions of the buttons. To resume normal operation of keypad, adjust setting so that LCK=NO.

CONTROLLER AUTOTUNING IN PID MODE

Before starting
 In the setup mode (see configuration parameters), set ICM=PID: make sure that ICM matches the desired operation mode (ON=REF for refrigerating control, ON=HEA for heating control), then adjust setpoint 1SP at the desired value.

Start autotuning

During normal operation, keep button **ENTR** pressed for 3 seconds. ICT blinks on the display. With **ENTR** and the cycle time in order to define the dynamic of the process to be controlled. To abort the autotuning function, press **ENTR** to start autotuning press **ENTR** or wait for 30 seconds.

During autotuning

During the entire autotuning phase, the display alternates TUN with the actual temperature measured. In case of power failure, when power is resumed, after the initial autotuning phase, the controller resumes the autotuning function. To abort the autotuning, without modifying the previous control parameters, keep button **ENTR** pressed for 5 seconds. After the autotuning has taken place successfully, the controller updates the control parameters and starts the control.

Errors

If the autotuning function failed, the display shows an error code:

- E1 (timeout) error: the controller could not bring the temperature within the proportional band. Increase 1SP in case of heating control, vice versa, decrease 1SP in case of refrigerating control and re-start the process.
- E2 (timeout) error: the autotuning has not ended within the maximum time allowed (1000 cycle times). Re-start the autotuning process and set a longer cycle time ICT.
- E3 (temperature overrange): check that the error was not caused by a probe malfunction; then decrease 1SP in case of heating control, vice versa increase 1SP in case of refrigerating control and then re-start the process.

Control improvement

- To eliminate the error indication and return to the normal mode, press button **ENTR**
- To reduce overshoot, reduce the integral action reset IAR
- To increase the response speed of the system, reduce the proportional band 1PB. Caution: doing this makes the system less stable.
- To reduce ringing in steady-state temperature, increase the integral action time IAT: system stability is thus increased, although its response speed is decreased.
- To increase the speed of response to the variations in temperature, increase the derivative action time IOT. Caution: a high value makes the system sensitive to small variations and it may be a source of instability.

RECALIBRATION

- Have a precision reference thermometer or a calibrator to hand. Ensure that OS1=0 and 5M=0.
- Switch the controller off then on again.
- During the run test phase, press button **ENTR** and keep then pressed till the controller shows 0AD.
- With button **INCR** and **DECR** adjust 0AD or 0AD2. 0AD2 allows a calibration of 0, inserting a constant correction over the whole scale of measurement. 0AD allows a calibration of the top part of the measurement scale with a proportional correction between the calibration point and 0.
- Press **ENTR** to display the value and then use **ENTR** and **INCR** to make the read value coincide with the value measured by the reference instrument.
- Exit from calibration by pressing button **ENTR**

CONFIGURATION PARAMETERS

- To get access to the parameter configuration menu, press button **ENTR** for 5 seconds.
- With button **INCR** select the parameter to be modified.
- Press button **ENTR** to display the value.
- By keeping button **ENTR** pressed, use button **INCR** to set the desired value.
- When button **ENTR** is released, the newly programmed value is stored and the following parameter is displayed.
- To exit from the setup, press button **ENTR** or wait for 30 seconds.


PAR	RANGE	DESCRIPTION
SCL	1°C / 2°C / 5°F	Resolution scale (see table of input specifications). Caution: upon changing the SCL value, it is then necessary to reconfigure the parameters relative to the absolute and relative temperature (2SM, 5PB, 1SP, 1HY, etc.).
SPL	5SP - 5PH	Minimum limit for output setting
SPH	5PL - 5SP	Maximum limit for 1SP setting
1SP	5PL - 5PH	Setpoint (value to be maintained in the room)
1CM	HY; PD	Control mode. With ICM=HY you select control with hysteresis; parameters 1HY, 1TB and 1TS are used. With ICM=PD you select a Proportional-Integral-Derivative control mode; parameters 1PB, 1I, 1D, 1AR, 1OT, 1AT and 1IT are used.
1CH	REF; HEA	Refrigerating (REF) or Heating (HEA) control mode.
1HY	0 - 15.5'	ON/OFF hysteresis differential. With 1HY=0 the output is always off. After output 1 has been turned off, it remains inactive for 1TB minutes regardless of the temperature value measured.
1TB	0 - 30min	Minimum off-time. After output 1 has been turned off, it remains inactive for 1TB minutes regardless of the temperature value measured.
1TI	0 - 30min	Minimum on-time (the following parameter will be 1PB). After output 1 has been turned on, it remains active for 1TI minutes regardless of the temperature value measured.
1PB	0 - 15.5'	Temperature control takes place by changing the ON time of the output: the closer the temperature to the setpoint, the less time of activation. A small proportional band increases the promptness of response of the system to temperature variations, but tends to make it less stable. A purely proportional control stabilizes the temperature within the proportional band but does not cancel the deviation from setpoint.
1IT	0 - 5.00s	Integral action time. The steady-state error is cancelled by inserting an integral action. The integral action time, determined the speed with which the steady-state temperature is achieved, but a high speed (IT low) may be the cause of overshoot and instability in the response. With 1IT=0 the integral control is disabled.
1DT	0 - 5.00s	Derivative action time. Response overshoot may be reduced by inserting a derivative action. A high derivative action (1DT high) makes the system very sensitive to small temperature variations and causes instability. With 1DT=0 the derivative control is disabled.
1AR	0 - 100%	Reset of integral action time referred to 1PB. Decreasing the parameter 1AR reduces the integral control action zone, and consequently the overshoot (see figure on paragraph 1IT).
1CT	1 - 255s	Cycle time: it's the period in which the output ON time changes. The quicker the system to be controlled reacts to temperature variations, the smaller the cycle time must be, in order to obtain higher temperature stability and less sensitivity to load variations.
1PP	ON/OFF	Output state in case of probe failure.
0AU	NCR; THR; ALD; AL1	Alarm output operation. NCR: output disabled (always off). (the next parameter will be ATM). THR: output programmed for second thermostat control (the next parameter will be 2SM). ALD: contacts open when an alarm condition occurs (the next parameter will be ATM). AL1: contacts make when an alarm condition occurs (the next parameter will be ATM).
2SM	ABS; REL	Setpoint 2 mode. Channel 2 setpoint may be absolute (2SM=ABS), or a differential relative to setpoint 1 (2SM=REL).
2SP	SPL - 5PH	Auxiliary output setpoint temperature (the next parameter will be 2DF).
2DF	-15.5 - 15.5'	Temperature differential relative to 1SP. The auxiliary output setpoint is equal to 1SP-2DF (ON/OFF control in refrigeration; Setpoint 2 relative to setpoint 1 (0AM=THR, 2CM=HEA)) or 1SP+2DF (ON/OFF control in heating; Setpoint 2 relative to setpoint 1 (0AM=THR, 2CM=HEA)).

OUT/TIME	REF/HEA	DESCRIPTION
2CH	REF; HEA	Refrigerating control (REF) or heating control mode (HEA) for the auxiliary output.
2HY	0 - 15.5'	Differential of thermostat 2. With 2HY=0 the auxiliary output always remains off.
2TO	0 - 30min	Minimum off-time. After output 2 has been turned off, it remains inactive for 2TO minutes regardless of the temperature value measured.
2TI	0 - 30min	Minimum on-time. After output 2 has been turned on, it remains active for 2TI minutes regardless of the temperature value measured.
2PF	ON/OFF	Auxiliary output state in case of probe failure.
ATM	NCR; ABS; REL	Alarm threshold management. NCR: all temperature alarms are inhibited (the following parameter will be 5B). ABS: the values programmed in ALA and AHA represent the real alarm thresholds. REL: the values programmed in ALB and AHB are alarm thresholds referred to 1SP and 1SP-1HY.
ALA	-5' - 15.5'	Low temperature alarm threshold.
AHA	ALA - 15.5'	High temperature alarm threshold.
ALR	-12.5 - 5'	Low temperature alarm differential. With ALR=0 the low temperature alarm is excluded.
AHR	0 - 12.5'	High temperature alarm differential. With AHR=0 the high temperature alarm is excluded.
ATD	0 - 120min	Delay before alarm temperature warning.
5B	NCR/YES	Standby by default enabling.
INP	DualMax; TV/2; ST/2SM	Sensor input selection (see table of input specifications).
RLO	-15.5 - 255	Minimum range value (in the modes AC1-2TA, AC1-2T, only). RLO takes the minimum value measured by the transmitter (i.e. the value matching 0V (blank)).
RHI	RL - 0 - 99.9	Maximum range value (in the modes AC1-2TA, AC1-2T, only). RHI takes the maximum value measured by the transmitter (i.e. the value matching 1V (20mA)).
OS1	-12.5 - 12.5'	Probe T1 offset.
TLD	1 - 30min	Delay for minimum temperature (TLO) and maximum temperature (TH) logging.
SIM	0 - 100	Display slowdown.
ADR	1 - 255	AC1-27 address for PC communication.

INPUT SPECIFICATIONS

MODEL	INPUT	RANGE (MEASUREMENT ACCURACY)		
		3CL-1°C	3CL-2°C	3CL-5°F
AC1-2TA	0-1V	RLO-RHI [± 0.3mV]		
AC1-2TL	0-20mA 0-5V 0-20mA 4-20mA	RLO-RHI [± 0.2mV]		
AC1-2TJ	INP=1 TC 'C / 'F	-50-150°C [± 0.2°C]	-50-600°F [± 0.5°F]	
AC1-2TJ	INP=2 TC 'C / 'F	-50-150°C [± 0.2°C]	-50-600°F [± 0.5°F]	
AC1-2TR	PT100	-50-150-99.999°C [± 0.2°C]	-100-650°C [± 0.2°C]	-50-600°F [± 0.5°F]
AC1-2TR	PTC 1000 D (EAE ST. 1)	-50-150-99.999°C [± 0.2°C]	50-150°C [± 0.2°C]	50-300°F [± 0.5°F]
AC1-2TJ	INP=ST1 PTC 1000 D (EAE ST. 1)	-50-150-99.999°C [± 0.2°C]	50-150°C [± 0.2°C]	50-300°F [± 0.5°F]
AC1-2TJ	INP=ST2 NTC 10K D (EAE ST. 1)	-40-150-99.999°C [± 0.2°C]	-40-150°C [± 0.2°C]	-40-300°F [± 0.5°F]

WIRING DIAGRAMS



TECHNICAL DATA

Power supply

AC1-27: D 12Vdc±10%, 2W
 AC1-2T: E 230Vac±10%, 50/60Hz, 2W
 AC1-2J: L 110Vac±10%, 50/60Hz, 2W

Relay outputs (AC1-27...R...)

OUT1 16VA
 OUT2 16VA

SSR drive (AC1-27...M...)

OUT1 15VA 12Vdc

Inputs

see table of input specifications

Measurement range

see table of input specifications

Measurement accuracy

see table of input specifications

Operating conditions

-15...+50°C, 50%, 80%

CE (Reference Norms)

EN60730-1; EN60730-2-8; EN50522 (Class B); EN50522-1

Front protection

IP55



CZ004936

CZ004940

PARAMETERS	MTBRX	ITBRX	GTBRX	MTBRX	ITBRX	GTBRX
SPH	45	45	45	45	45	45
1SP	35	35	32	35	35	32
1HY	3.0	3.0	3.0	3.0	3.0	3.0
1CH	REF	REF	REF	-	-	-
1T0	0	0	0	-	-	-
1T1	0	0	0	-	-	-
1CT	-	-	-	0.1	0.1	0.1
1PF	ON	ON	ON	ON	ON	ON



Main Offices & Production Plant

364 Varis-Koropiou Ave. Koropi
194 42 Athens, Greece

Headquarters

A.I.S. GmbH
75438 Knittlingen, Germany

email contact@carbonzapp.com

tel +30 210 9856110

fax +30 210 9928655

Support / Sales Telephone

+30 210 98 56110

Support email

support@carbonzapp.com

TeamViewer email

tv@carbonzapp.com

Sales email

office@carbonzapp.com

carbonzapp.com